

Date: October 17, 2006

File number: 26681-AP-AE-06-0082

**MODIFICATION ACCEPTANCE LETTER (MAL)  
FOR  
Approved Meters and Devices**

**Type of Device**

Instrument Transformer: Current, Voltage

**Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

**Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

**Approval Numbers**

AE-1029

**Applicant**

La Prairie Inc.  
1206 Ringwell Drive, Units 5 & 6  
New Market, Ontario, Canada  
L3Y 8V9

**Description of Modifications**

The combination transformer 300/600-5A double current ratio with 16100-115V voltage ratio has a rating factor of 1.5 and an accuracy of 0.3WXY for the voltage."

Original signed by:  
Claude G. Renaud  
Technical Coordinator – Electricity Measurement



Date: 17 octobre 2006

Dossier: 26681-AP-AE-06-0082

**LETTRE D'ACCEPTATION DE MODIFICATION (LAM)**  
**pour**  
**Compteurs et Appareils Approuvés**

**Type d'Appareil**

Transformateur de mesure: courant, tension

**Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

**Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

**Numéros d'approbation**

AE-1029

**Requérant**

La Prairie Inc.  
1206 Ringwell Drive, Units 5 & 6  
New Market, Ontario, Canada  
L3Y 8V9

**Descriptions des modifications**

La combinaison de transformateur de courant à rapport double 300/600-5A avec le rapport de tension 16100-115V à un facteur de surcharge de 1,5 et une classe de précision de 0,3WXY pour le voltage.

Copie authentique signée par :

Claude G. Renaud  
Coordonnateur technique – Mesure de l'électricité