



Measurement Canada  
An Agency of Industry Canada

Mesures Canada  
Un organisme d'Industrie Canada

MAL No. - N° De LAM

**MAL-E144**

Date: March 25, 2008

File number: 26681-AP-AE-07-0191

**MODIFICATION ACCEPTANCE LETTER (MAL)  
FOR  
Approved Meters and Devices**

**Type of Device**

Electricity Meter: Energy and Demand

**Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

**Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

**Approval Numbers**

AE-0924

**Applicant**

Power Measurement Limited  
A Division of Schneider Electric  
2195 Keating Cross Road  
Saanichton, BC  
V8M 2A5

**Description of Modifications**

Version V281 is included in the list of approved firmware for ION 8300, ION 8400, and ION 8500 only. It fixes an incompatibility with the TCP/IP Stack that was present in V280.

Original signed by:

Isabelle Tremblay

Acting Technical Coordinator – Electricity Measurement



Measurement Canada  
An agency of Industry Canada

Mesures Canada  
Un organisme d'Industry Canada

MAL No. - N° De LAM

**MAL-E144**

Date: 25 mars 2008

Dossier: 26681-AP-AE-07-0191

## **LETTRE D'ACCEPTATION DE MODIFICATION (LAM)**

**pour**

### **Compteurs et Appareils Approuvés**

#### **Type d'Appareil**

Compteurs Électrique: Énergie et maximum

#### **Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

#### **Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

#### **Numéros d'approbation**

AE-0924

#### **Requérant**

Power Measurement Limited  
A Division of Schneider Electric  
2195 Keating Cross Road  
Saanichton, BC  
V8M 2A5

#### **Descriptions des modifications**

La version de progiciel V281 est été ajoutée à la liste des versions approuvées pour ION 8300, ION 8400, et ION 8500 seulement. Ceci corrigera l'incompatibilité avec le pile TCP-IP qui était présente dans la version V280.

Copie authentique signée par :

Isabelle Tremblay

Coordonnatrice technique intérimaire – Mesure de l'électricité