



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file *Votre référence*

Our file *Notre référence*

Telephone: (613)952-0635

File N': 06565
Project: AP-EL-93-0005
 AP-EL-93-0006
 AP-EL-93-0007
 AP-EL-93-0008

General Electric Canada Inc.
1130 Boul. Charest Ouest
Quebec, Quebec
G1N 2E2
Attention: Mr. Gerard Chevalier

1993-08-12

Dear Mr. Chevalier:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notices of Approval E-24, E-172, E-273 and AE-0352. It is noted that these devices are to be modified as follows:

- Lag adjust coils in the current circuits may be eliminated, to be replaced
- by lag adjust resistors in series with the potential coils.

I am advised by the Metrology Laboratory that their evaluation of the proposed modifications indicates that they do not adversely affect the performance of the meter. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approvals. All recipients of the approval notices are being informed by copy of this letter.

Yours truly,

H.L. Fraser, Chief
Electricity and Gas

cc: Approvals Mailing List

Canada