



Industry
Canada

Industrie
Canada

Legal Metrology
Branch

Direction de la
métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa (Ontario)
K1A 0C9

Telephone: (613) 952-0635
FAX: (613) 952-1754

Téléphone: (613) 952-0635

File No.: 06565-C2-6
Project: AP-EL-94-0020
Date: 1994-09-20

Mississauga Hydro
3240 Mavis Road
Mississauga, Ontario
L5C 3K1

Attention: Mr. Carl Switzer, Metering Manager

Dear Mr. Switzer:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notices of Approval E-24, E-45 and E-177. It is noted that General Electric Type VM-65S meters may be modified as follows:

1. Replacement of the M-50 block interval demand register by the General Electric mechanical kilowatt hour register used on the General Electric Type V-65S meter;
2. Removal of the potential leads which supply power to the M-50 block interval demand register;
3. Installation of a new nameplate showing the type designation "V-65S", Notice of Approval number E-24 and all other currently required information; and
4. Retention of the original VM-63S-5 glass cover.

I am advised by the Electrical Metrology Laboratory that its evaluation of the proposed modification indicates that it may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modification is accepted as being included within the above-noted approval. All recipients of the notice of approval are being informed by copy of this letter.

Yours truly,

A handwritten signature in black ink, appearing to read 'H.L. Fraser', with a long horizontal flourish extending to the right.

H.L. Fraser, Director
Electricity and Gas

cc: Approvals Mailing List



**Industry
Canada**

**Legal Metrology
Branch**

Holland Avenue
Ottawa, Ontario
K1A 0G9

Telephone: (613) 952-0635
FAX: (613) 952-1754

**Industrie
Canada**

**Direction de la
métrologie légale**

Avenue Holland
Ottawa (Ontario)
K1A 0G9

Téléphone: (613) 952-0635

File No.: 06565-C2-6
Projet: AP-EL-94-0020
Date: 1994-09-20

Mississauga Hydro
3240 Mavis Road
Mississauga, Ontario
L5C 3K1
Attention: M. Carl Switzer, Gérant du mesurage

Monsieur,

Nous accusons réception de l'avis de modification que vous nous avez envoyé récemment conformément à l'article 13 du Règlement sur l'inspection de l'électricité et du gaz, au sujet des appareils approuvés en vertu des avis d'approbation E-24, E-45 et E-177. Il est à noter que les compteurs de type VM-65S de la Générale Électrique peuvent être modifiés comme suit:

1. Remplacement de l'enregistreur de maximum à intervalle d'intégration M-50 par l'enregistreur mécanique de kilowattheures de la Générale Électrique utilisé sur les compteurs de type V-65S de la Générale Électrique;
2. Retrait des conducteurs de potentiel alimentant l'enregistreur de maximum à intervalle d'intégration M-50;
3. Installation d'une nouvelle plaque signalétique indiquant le type "V-65S", l'avis d'approbation E-24 et tous les autres renseignements normalement exigés; et
4. Conservation du couvercle initial en verre VM-63S-5.

...\2

Canada

Après avoir étudié les modifications proposées, le Laboratoire de l'électricité (Métrologie légale) me signale que ces modifications ne contreviennent en rien aux dispositions de la Loi. En conséquence, les modifications sont acceptées et intégrées de facto dans les avis d'approbation susmentionnés. Tous ceux qui ont reçu les avis d'approbation sont avisés de cette décision par une copie de la présente lettre.

Je vous prie d'agréer mes salutations distinguées.

A handwritten signature in black ink, appearing to be 'H.L. Fraser', with a long horizontal flourish extending to the right.

H.L. Fraser, Directeur
Électricité et gaz

c.c.: Liste d'envoi des approbations