



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

NOTICE OF APPROVAL
AVIS D'APPROBATION

E-59-1

Ottawa, Sept. 27, 1976

STATREL TYPES M-31M AND M-32M INTERPOSING RELAYS

This notice constitutes an addition to Approval Notice E-59, October 29, 1973 which remains in effect.


The Types M-31M and M-32M interposing relays are the same as the Types M-31 and M-32 interposing relays except for the output relay. The dry reed relay Type SR-1045 has been replaced by a SPDT Form C, Mercury Wetted Contact Relay, C.P. Clare Type HGSM 51111 P00.


Output Contact Rating (Resistive Load)
Power 100 VA, maximum
Voltage 500 V, dc or ac, maximum
Current 2A, maximum

NOTE: Because of the mercury wetted relay used the Interposing Relays Models M-31M and M-32M must be mounted upright. An arrow on the name plate beside the words "Mount Upright" indicates the correct mounting configuration.

Approval granted to:

Statrel Limited,
Port Credit, Ontario.


J. L. Armstrong, P. Eng.,
Chief, Standards Laboratory,
Metrology & Laboratory Services.


D.L. Smith, P. Eng.,
Chief, Electricity & Gas Division,

Ref: G 6565-S688-43