



Consommation et Corporations Canada      Consumer and Corporate Affairs Canada

Direction de la Métrologie légale      Legal Metrology Branch

Holland Avenue      Avenue Holland  
Ottawa, Ontario      Ottawa, Ontario  
K1A 0C9      K1A 0C9

Legal Metrology Laboratories  
Telephone: (613) 990-8621

Your file      Votre référence

Our file      Notre référence

O6565-S2-6  
June 27, 1985  
AML-E-11

Sangamo Canada  
Division of Schlumberger Canada Limited  
215 Laird Drive  
Toronto, Ontario  
M4G 3X1  
Attention: Mr. M. Purc, P. Eng.  
Director of Engineering

Dear Mr. Purc:

This letter is in response to your letter dated June 21, 1985, regarding the modification to the types KY, KYL, KYW, KYQ, KYR and K300 damping magnet assemblies by substituting a stainless steel anchor spring for the two bolts, nuts and springs formerly used to secure the adjustment plates, which are currently approved in Notices of Approval E-60, E-65, E-66, E-71, E-96, E-137, E-181 and subsequent dash numbers to these basic approvals. I am advised that the Electrical Laboratory has evaluated this modification and concluded that it may be regarded as insignificant, in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by copy of this letter.

Yours truly

W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

Canada