



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



**STANDARDS BRANCH - DIRECTION DES NORMES**

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

**E-82-1**

OTTAWA December 2, 1974

CANADIAN WESTINGHOUSE TYPE "D4A" SINGLE PHASE  
WATTHOUR METERS

This notice is an extension of Approval E-82 to include "A" base meters.

Description

The bearings, discs, disc shafts, electromagnets, frames and registers are identical in both "A" and "S" base configurations.

The base and glass cover are the same as used in the type "D2A" covered by Approval S-EA. 477.

The "A" base meters are fitted with current coils and terminal blocks manufactured by Ferranti-Packard and are interchangeable with the type "B5A" watthour meter covered by Approval E-111.

Approval granted to:

Canadian Westinghouse Company Ltd.,  
Hamilton, Ontario.

J. L. Armstrong,  
Chief, Standards Laboratory,

D. L. Smith,  
Chief, Electricity & Gas Division,  
Metrology and Laboratory Services.

Ref: GL 1145-57/C3-882  
GL 1145-57/F2-881