*

Consumer and Corporate Affairs Canada

Consommation et Corporations Canada

Legal Metrology Branch Direction de la Métrologie légale

Holland Avenue Ottawa, Ontario K1A 0C9 Avenue Holland Ottawa, Ontario K1A 0C9

Your file Votre référence

Telephone: (613)952-0640

Our file Notre référence

File N': 06565

Project: AP-EL-89-0079

1989-12-21

Iris Systems Inc. 355-435 Ellice Ave. Winnipeg, Manitoba R3B 1Y6

Attn.: Mr. Dave Whelan

Dear Sir:

This is in response to your recent notification given in accordance with the Electricity and Gas Regulations, Section 13, regarding devices approved under Notices of Approval E-88 Rev. 14, E-116, E-121, E-224, E+228 and E-240. It is noted that these devices are to be modified as follows:

- Manufacturer's nameplate is removed.
- Iris Systems Inc. Communicating Meter Encoder (CME) is installed for purpose of trial of Automatic Meter Reading (AMR) system.
- · CME consists of Sensor Card Assembly, Transmitter Card Assembly and Antenna Board.
- Segment of meter disk painted with flat black enamel.
- No moving parts of meter touched by CME.
- Information on original meter nameplate transferred in total to adhesive label affixed to teflon Transmitter Card Assembly.
- CME and AMR shall not be used for billing purposes.

I am advised by the Electrical Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

W.R. Virtue, Chief

Legal Metrology Laboratories

cc: Approvals Mailing List

Canada a