



Consumer and
Corporate Affairs

Consummation of
corporations

Standards

Normes

NOTICE OF APPROVAL
AVIS D'APPROBATION

E-88-4

September 23, 1975

Ottawa, _____

NEW CURRENT COIL CONFIGURATION FOR CANADIAN GENERAL
ELECTRIC I-70S SINGLE PHASE METERS

This notice constitutes an addition to E-88,
E-88-1, E-88-2 and E-88-3 which otherwise remain in effect.


Description

The new current coils are designed to give improved coil balance to the I-70S meter. They are distinguishable from the old ones only by the fact that they fit around the core more closely and have slightly modified shape.

Approval granted to:

Canadian General Electric Co. Ltd.,
1130 Blvd. Charest West,
Quebec, P.Q.
G1N 2E2


J. L. Armstrong,
Chief, Standards Laboratory,


D.L. Smith,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services.

Ref: GL 1145-57/C2-530