



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-88-5

January 9, 1978

Ottawa, \_\_\_\_\_

**CANADIAN GENERAL ELECTRIC TYPE "I-70S" SINGLE PHASE WATT HOUR  
METER FOR USE WITH ADAPTOR ON SINGLE PHASE 2-WIRE 120 VOLT  
60 HZ CIRCUITS**

---

This Notice constitutes an amendment to E-88-3 which remains in effect.

Description

This modification consists of the installation of a "figure 8" shaped resistance wire around the current core legs. This is said to improve the performance at lagging load.

If the meter is to be converted to 240V, 3W operation, this ~~twin~~ is to be removed.

*turn*

These meters are to be verified through 100% inspection.

Approval granted to:

Canadian General Electric Co. Ltd.,  
1130 Boulevard Charest,  
Quebec, P.Q.

D.L. Smith, P. Eng.,  
Chief, Electricity & Gas Division,  
Legal Metrology Branch.

Ref: 6565-C2-7