



**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-88-6

Ottawa, October 2, 1978

CANADIAN GENERAL ELECTRIC TYPE I-70A TR AND TYPE I-70 S TR  
SINGLE PHASE WATT HOUR METERS

This notice constitutes an addition to E-88, E-88-1, E-88-2, E-88-3, E-88-4 and E-88-5 which otherwise remain in effect.

Current Range:	0.12 - 10 amperes	
Voltage:	120	240
Frequency:	60 Hz	
Wire:	I-70S TR: 2	I-70A TR: 2 or 3
Kh:	120 volts: 0.3	240 volts: 0.6
*Register Ratio:	166 2/3 4 dial clock with test dial	

\*Register will have "MULT. X" stencilled on the lower right face.

Description

The watt hour meters covered by this approval notice have the same exterior dimensions and appearance as the previously approved I-70 Single Phase Watt Hour Meters. The wiring connections are the standard connections for 2 wire and 3 wire transformer rated meters.

The nameplate is marked transformer type and spaces are designated for PT and CT ratios as well as primary kh.

NOTE: The I-70A TR and I-70S TR Meters have a shield just above the meter lag plate to reduce the effect of magnetic fields on the meter.

Approval granted to:

Canadian General Electric,  
1130 Boulevard Charest, West,  
Quebec, P.Q.

D.L. Smith,  
Chief,  
Electricity and Gas Division,  
Legal Metrology Branch.

Ref: G 6565-C2-7

