



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-88-8

Ottawa, July 15, 1980

CANADIAN GENERAL ELECTRIC TYPE I-70A
SINGLE PHASE WATT HOUR METER FOR USE
ON SINGLE PHASE 2 WIRE 120 VOLT 60 Hz


Current range: 1.0-100 Amperes
Voltage: 120 Volts
Frequency: 60 Hz
Wire: 2
Kh 1.8 watt hours per rev.
Rr 55 5/9
Register Type: 4-Dial x 1 clock with test dial

Description

The watt hour meters covered by this Notice of Approval have the same exterior dimensions and appearance as the previously approved I-70A single phase watt hour meters.

Wiring connections conform to the standard single phase, 2 wire, A base, self-contained meter.

Approval granted to: Canadian General Electric Co. Limited
1130 West Charest Blvd
Quebec (Quebec)
G1N 2E2


J. Armstrong, Acting Chief,
Electricity and Gas Division,
Legal Metrology Branch.

Ref: G6565-C2-7