



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

NOTICE OF APPROVAL
AVIS D'APPROBATION

E-112-2

Ottawa, September 29, 1975

LANDIS & GYR TYPE ZFR1----, AND TYPE ZMR1----
ELECTRONIC WATTHOUR METERS

This is a revision of Notice of Approval E-112-1
which remains in effect.

The current Range of these meters is changed
from 0.12-10A to 0.05-10A.

J.L. Armstrong,
Chief, Standards Laboratory,

D.L. Smith,
Chief, Electricity and Gas Division,
Metrology & Laboratory Services

Ref: GL 1145-57/L1-153