



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL - AVIS D'APPROBATION

NO.

E - 117

DATE

November 2, 1972.

CANADIAN GENERAL ELECTRIC 5-DIAL X 1 CLOCK REGISTER CONVERTED
TO 4-DIAL X 10 REGISTER

Apparatus: All approved 5-dial X 1 Clock Registers with
and without test dials

Description: The conversion consists of a small aluminum
disc that replaces the hand on the first reading dial shaft.


The radius of the disc is slightly larger
than that of the registers so that the numerals and division
marks are effectively covered.

By thus blanking out the first reading dial,
the second dial becomes the units dial, so that it is necessary
to apply a multiplier of 10 to the remaining four dials in
order to arrive at the correct consumption. To draw attention
to this, the disc has "mult X 10" marked on it.

This conversion is intended as an aid to
those utilities that have watt-hour meters with 5-dial registers
but have tabulating equipment that can handle only 4 digits.


It is well to note that when these registers
with the disc in place are read, the second dial, which has
become the units dial because of the disc, rotates in the
reverse direction to that of the units dial of a standard 4-
dial X 10 register.

...2




Approval granted to:

Canadian General Electric Company Ltd.,
1130 Boulevard Charest
Quebec 8, P. Q.



J.S.T. Swanson, P. Eng.
Chief, Standards Laboratory,
Standards Branch



W.J.S. Fraser,
Chief, Electricity and Gas Division
Standards Branch.

Ref: SL-100-883K
1145-57/C2-530