



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL

E - 119

OTTAWA January 23, 1973.

CANADIAN WESTINGHOUSE 5-DIAL X 1 CLOCK REGISTERS
CONVERTED TO 4-DIAL X 10 REGISTERS

Apparatus: All approved 5-Dial X 1 Clock Registers

Description: The conversion consists of a small aluminum disc that is pressed on the shaft above the pointer of the first reading dial.

By thus blanking out the first reading dial the second dial becomes the units dial, so that it is necessary to apply a multiplier of 10 to the remaining four dials in order to arrive at the correct consumption. To draw attention to this, the disc has "mult X 10" marked on it.

This conversion is intended as an aid to those utilities that have watt-hour meters with 5-dial registers but have tabulating equipment that can handle only 4 digits.

It is well to note that when these registers with the disc in place are read, the second dial, which has become the units dial because of the disc, reads in the reverse direction to that of the units dial of a standard 4-dial X 10 register.