



Legal Metrology Laboratories
 Standards Building
 Tunney's Pasture, Holland Avenue
 Ottawa, Ontario
 K1A 0C9
 Telephone: (613) 995-0930

AML/E-2

Votre référence Your file
 Notre référence Our file

G6565-S2-7
 January 31, 1984

Sangamo Canada
 (Division of Schlumberger Canada Limited)
 215 Laird Drive
 Toronto, Ontario
 M4G 3X1

Attn: Mr. M. Purc, P. Eng.
 Director of Engineering

S-PH. WH. MTR.

Dear Mr. Purc:

This is in response to your letter of January 25, 1984 regarding the modification to the meter bases of types K2S, K2WS and K2LS single phase watt hour and combination meters, previously approved under Notices of Approval E-121, E-124 and E-171-1 respectively. I am advised that the Electrical Laboratory has evaluated the re-location of the filter from the back of the base to the bottom of the meter rim below the gasket and has concluded that it may be regarded as insignificant in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act:

1. Your letter and sample is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561; and
2. The proposed alteration is hereby accepted, in accordance with the aforementioned subsection as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by a copy of this letter.

Yours truly,

W.R. Virtue
 Chief,
 Legal Metrology Laboratories

cc: Electrical Approvals Distribution List

Canada