Consumer and Corporate Affairs Canada et Corporations Canada

Consommation

Legal Metrology Branch

Direction de la Métrologie légale

207 Queen Street Ottawa, Ontario K1A 0C9

207 Rue Queen Ottawa, Ontario K1A 0C9

Your file Votre référence

Our file Notre référence

Legal Metrology Laboratories Telephone: (613) 952-0615

> 06565-C3-7 March 10, 1988 AML-E-38

Westinghouse Canada Inc. Box 1600 Alliston, Ontario LOM 1A0

Attention: Mr. K.E. Newbold, P. Eng.

Dear Mr. Newbold:

This is in response to your letter dated March 9, 1988, regarding Notices of Approval E-122, 149, 194, 195, 211, 212 and subsequent additions and revisions, and proposing to modify the meter blades approved therein by forming them from pre-plated copper material instead of plating them after forming.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as immaterial in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

- your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
- the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue

Chief

Mailing List (Electrical Approvals)