

NOTICE OF APPROVAL  
AVIS D'APPROBATION

E-137

Ottawa, March 17, 1976SANGAMO TYPE KYQO POLYPHASE "Q"-HOUR METERS

Elements	Current Range (amperes)	Volts	Kh	Register Ratio	
				4 and 5 dial x 1	4 dial x 10
2	0.12 - 10	120	0.72	166-2/3	1666-2/3
		240	1.44	83-1/3	833-1/3
		480	2.88	41-2/3	416-2/3
		600	3.60	33-1/3	333-1/3
2-½ wye	0.12 - 10	120	1.08	111-1/9	1111-1/9
		240	2.16	55-5/9	555-5/9
		345	3.24	37-1/27	370-10/27
3 wye	0.12 - 10	120	1.08	111-1/9	1111-1/9
		240	2.16	55-5/9	555-5/9
		345	3.24	37-1/27	370-10/27

- (1) Frequency 50 and 60 Hz
- (2) Phase Rotation ABC shown on nameplate circuit diagrams.
- (3) 2-Element "Q"-hour meter cannot be used with delta connected current transformers to measure 3 phase 4 wire wye service.
- (4) 2-½ Element and 3-Element wye 240 volt 60Hz meters are approved for use on 277 volts without recalibration.
- (5) All registers are clock type with test dials.
- (6) All meters can be supplied with potential indicating lamps.
- (7) All ratings are available in "S", "P", "F" and "FD" bases.
- (8) All meters are fitted with type "O" pulse initiator (E-120) and a reverse running detent.

**Burden Data:**




Voltage Coil (at rated voltage) all types.

60 Hz 1.0W 7.9va 7.8rva  
 50 Hz 1.25w 9.7va 9.6rva

Current Coil (at 5 amps)

2-Element

60 Hz (single coil) 0.95w 3.90va 3.75rva  
 50 Hz (single coil) 0.95w 3.35va 3.20rva



Current Coil (at 5 amps) (con'd)

2- $\frac{1}{2}$ -Element wye

60 Hz coils A and C	0.47w	1.95va	1.87rva
split coil B	0.95w	3.90va	3.75rva
50 Hz coils A and C	0.47w	1.67va	1.60rva
split coil B	0.95w	3.35va	3.20rva

3-Element wye

60 Hz (single coil)	0.95w	3.90va	3.75rva
50 Hz (single coil)	0.95w	3.35va	3.20rva

Description

The "Q"-hour meters, herein granted approval, are similar to the type "KY" transformer type polyphase watt-hour meters described in Approval Notice E-60 except that, to produce the 60° potential lag relative to an equivalent watt-hour meter, the meters are connected internally as follows:

2-Element

Current connections unchanged.  
Voltage connections cross-phased to introduce a 60° lag.

2 $\frac{1}{2}$ -Element

Current connections reversed and shifted 120° to introduce a 60° lag.  
Voltage connections unchanged.


3-Element


Current connections unchanged.  
Voltage connections reversed and shifted 120° to introduce a 60° lag.

Watt-hour meters will be used in conjunction with type KYQO "Q"-hour meters in order to determine load power factor. External connections to meter bases are exactly the same as associated watt-hour meters. However, when connecting for single phase test, the internal wiring of individual coils must be taken into account. For single phase test purposes "Q"-hour meters are to be treated as watt-hour meters.

Approval granted to:

Sangamo Company Limited,  
Toronto, Ontario.

  
J.L. Armstrong, P. Eng.,  
Chief, Standards Laboratory,  
Metrology & Laboratory Services

  
D.L. Smith, P. Eng.  
Chief, Electricity & Gas Division,