



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

NOTICE OF APPROVAL
AVIS D'APPROBATION

E-138

Ottawa, April 7, 1976

CANADIAN WESTINGHOUSE TYPE "D4A" SINGLE PHASE
WATTHOUR METERS

This amendment covers the use of the Sangamo aluminum base complete with the Sangamo hanger and sealing slider, and a Glass Cover from General Electric.

The Sangamo base is very close to the Westinghouse base dimensionally and the mounting arrangement of the electro-magnet and grid assembly to the base will be the same as used on the approved meters, Type D4A, under Approvals E-82-1 and E-133.

These changes are necessitated by the failure of the mould used to die cast the aluminum base and will be in use until a new mould has been manufactured.

Approval granted to:

Westinghouse Canada Ltd.,
Hamilton, Ontario.

J.L. Armstrong, P. Eng.,
Chief, Standards Laboratory,

D.L. Smith, P. Eng.,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services

Ref: GL 1145-57/C3-882