



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-144-1

Ottawa, May 18, 1978

SCIENTIFIC COLUMBUS DIGILOGIC SOLID STATE
WATT/WATT HOUR TRANSDUCER AND SCIENTIFIC
COLUMBUS MODEL 6153 DUAL WATT HOUR REGISTER

This notice constitutes an amendment to Notice of Approval E-144 to permit the use of any watt hour per pulse value (Kp) consistent with the requirements of the installation wherein the device is used.

Likewise the ratio of flashes to output pulses of the fast rate indicator may be of any value. Nameplate markings must correspond in each case.

Approval granted to:

Scientific Columbus Division of
Esterline Corp.,
Columbus, Ohio, U.S.A
Canadian Agent: R.G. Shelley Ltd.,
Don Mills, Ontario.

D.L. Smith,
Chief,
Electricity & Gas Division,
Legal Metrology Branch.

REF: G 6565-S771