

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-160-1

Ottawa, October 17, 1979

WESTINGHOUSE CANADA TYPES "D4S" and "D4A" METER REGISTER

This Notice constitutes an addition to Notice of Approval E-160, dated 3 August 1978, and covers register modifications for reasons of standardization and manufacturing efficiency.

Type	Clock
Dials	5
Dial Size	0.625 inch diameter
Test Dial	Yes
Multiplier	No
Register Ratio	13 8/9

The following modifications are hereby approved:

- a) Worm on number one shaft changed from 4-start to single-start.
- b) Gearing changes in number two shaft and number one counter shaft to maintain correct register ratio.

In construction, size, dial diameter and appearance, the modified registers are similar to the registers previously approved and are completely interchangeable with corresponding registers used on the "D-" line watt-hour meters since 1956.

Approval granted to:

Westinghouse Canada Ltd.,
Hamilton, Ontario.



D.L. Smith,
Chief, Electricity & Gas Division,
Legal Metrology Branch

Ref: G6565-C3-10