



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology  
Branch

Direction de la  
Métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

Your file    Votre référence

Legal Metrology Laboratories  
Telephone: (613) 952-0615

Our file    Notre référence

06565-S2  
AP-EL-87-0015  
June 2, 1987  
AML-E-31

Sangamo Canada  
215 Laird Drive  
Toronto, Ontario  
M4G 3X1  
Attention: Mr. C. Beaton

Dear Mr. Beaton:

This is in response to your letter dated May 11, 1987, regarding Notices of Approval E-175, and proposing to modify Type 02 Pulse Initiator approved therein by modifying the KYZ output circuitry as a customer option for reasons of compatibility with certain recorders or similar equipment.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as insignificant in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

1. your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

**Canada**