



Consommation
et Corporations Canada

Consumer and
Corporate Affairs Canada

Direction de la
Métrologie légale

Legal Metrology
Branch

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Legal Metrology Laboratories
Telephone: (613) 990-8621

Your file *Votre référence*

Our file *Notre référence*

O6565-S2-2
July 17, 1985
AML-E-13

Sangamo Canada
(Division of Schlumberger Canada Limited)
215 Laird Drive
Toronto, Ontario
M4G 3X1
Attention: Mr. Alan Clarke, P. Eng.
Engineering Department

Dear Mr. Clarke:

This letter is in response to your letter dated June 26, 1985, regarding the modification to the type K300 Demand-Energy Meters to provide optional recorder outputs, eliminating the diode voltage drop present in a closed contact condition, which are currently approved in Notice of Approval E-181. I am advised that the Electrical Laboratory has evaluated this modification and concluded that it may be regarded as insignificant, in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by copy of this letter.

Yours truly

W.R. Virtue
Chief

cc: Mailing List (Electrical Approvals)

Canada