



Consumer and Corporate Affairs Canada      Consommation et Corporations Canada

Legal Metrology Branch      Direction de la Métrologie légale

Holland Avenue      Avenue Holland  
Ottawa, Ontario      Ottawa, Ontario  
K1A 0C9      K1A 0C9

Legal Metrology Laboratories  
Telephone: (613) 990-8621

Your file    Votre référence

Our file    Notre référence

06565-S2-2  
May 26, 1986  
AML-E-19

Sangamo Canada  
(Division of Schlumberger Canada Limited)  
215 Laird Drive  
TORONTO, Ontario  
M4G 3X1  
Attn: Mr. M. Turner, P. Eng.  
Senior Application Engineer

Dear Mr. Turner:

This is in response to your letter dated May 16, 1986, regarding type K300 demand-energy meters, currently approved in Notices of Approval E-181 and E-181-1, and your intention to make available the following options:

- (1) an illuminated green LED to indicate a satisfactory battery condition which would go out in the event of battery failure; and
- (2) the legend "MAX" to indicate peak demand values together with a steady state display of the present demand legends in lieu of the current flashing display.

I am advised that, upon evaluation of the proposed modifications, the electrical laboratory has concluded that they may be regarded as insignificant in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act,

your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and

the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue  
Chief

**Canada**

cc: Mailing List (Electrical Approvals)