



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology  
Branch

Direction de la  
Métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

Legal Metrology Laboratories  
Telephone: (613) 952-0615

Your file    Votre référence

Our file    Notre référence

O6565-S668  
July 25, 1986  
AML-E-21

MDI-3 (Dem. Ind.)

Statrel Limited  
1200 Aimco Blvd.  
Unit 8  
MISSISSAUGA, Ontario  
L4W 1B2

Attn: L.C. Pearson

Dear Mr. Pearson:

This is in response to your letter dated July 17, 1986, regarding the Ontario Hydro Type MDI-3 Maximum Demand Indicator currently approved in Notice of Approval E-208, and your intention to make available this device with the Statrel name and logo instead of the Ontario Hydro name and logo.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as insignificant in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

1. your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

for/pou W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

Canada