

DEPARTMENT OF TRADE AND COMMERCE
Electricity and Gas Standards Laboratories


Ottawa, July 4th, 1930.

District Inspectors of Electricity & Gas:-

Dear Sirs, - I beg to advise you that the type P.S.1, 60 cycle, polyphase watt-hour meter, equipped with either a cyclometer or clock type dial, manufactured by the Packard Electric Company, Limited, St. Catharines, Ontario, has been approved by the National Research Council and may be admitted to verification in Canada.

This meter is very similar to the type P.S. meter, one change being the altering of full load speed from 50 R.P.M. to 25 R.P.M.

Yours truly,



Director.