

DEPARTMENT OF TRADE AND COMMERCE

Electrical and Gas Standards Laboratories


Ottawa, January 21st, 1931.

District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the type I.18 single phase, 3 wire, 2 element, 25 cycle meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council and may be admitted to verification in Canada.

This meter is similar to the type I.18, 60 cycle, meter approved by Circular N.R.C.2.

Yours truly,



Director.