

Department of Trade and Commerce
Electrical and Gas Standards Laboratories


Ottawa, February 5th, 1931.

District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the type HC, vertical, polyphase, three element watt-hour meter, manufactured by the Sangamo Electric Company of Canada, Limited, Toronto, Ontario, has been approved by the National Research Council and may be admitted to verification in Canada.

This meter will be built in the usual standard sizes for use on 25 and 60 cycle circuits and may be equipped with either a clock or cyclometer register.

Yours truly,



Director.