

DEPARTMENT OF TRADE AND COMMERCE

Electrical and Gas Standards Laboratories

Ottawa, February 6th, 1931.


District Inspectors of Electricity & Gas-

^{WD.}
Dear Sirs,- I beg to advise you that the type ~~HW-2~~ demand meter manufactured by the Lincoln Meter Company, Toronto, Canada, has been approved by the National Research Council and may be admitted to verification in Canada.

To facilitate reading the scale of this instrument the indicating pointer is to be painted black in order to provide sufficient contrast against the white color of the face of the dial.

You will note on the nameplate of this instrument the words "Test Period K Minutes", where "K" is a number appropriate to the instrument type concerned and is the time required for the instrument to indicate 99% of the maximum reading.

Yours truly,



Director.