

DEPARTMENT OF TRADE AND COMMERCE

Electrical and Gas Standards Laboratories

Ottawa, April 18th, 1931.


District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the 25 and 60 cycle type ED.3 polyphase Lincoln Sangamo demand energy meter, manufactured by the Sangamo Company Limited, Toronto, Canada, has been approved by the National Research Council and may be admitted to verification in Canada.

This meter is a development of the ED.3 single phase meter approved in February, 1931.

The meter will be built in the following capacities; $2\frac{1}{2}$, 5, 10, 15, 25, 50 and 100 amperes; and in voltages of standard rating, namely, 115, 230, 460 and 575.

Yours truly,



Director.