

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, February 28, 1934.

District Inspectors of Electricity & Gas:-

Dear Sirs,- Re-C.G.E. type IP.16, 3 wire
Prepayment Meter

I beg to advise you that the type IP.16, 3 wire prepayment meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes - 5, 10, 15 and 25
Volts - 230
Frequencies- 25 and 60 cycles.

Yours truly,


Director.

JLS/RS