

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, September 20th, 1934.

District Inspectors of Electricity and Gas:-

Dear Sirs,-

I beg to advise you that the following current transformers, manufactured by the Canadian General Electric Company, Toronto, Canada, have been approved by the National Research Council for use in Canada:

Type	Stand Rating amps.	Voltage of circuit	Frequency cycles	Usage
WF-1	5-800	5000	25 - 125	indoor
WF-2	5-800	5000-7500	25 - 125	"
K-50	1000-3000	7500	25 - 125	"
KC-50	1000-4000	7500	25 - 125	"
K-51	1000-4000	15000	25 - 125	"
K-48	5-800	15000	25 - 125	"
K-49	5-800	15001-25000	25 - 125	"
WF-6	5-400	5000	25 - 125	outdoor

Yours truly,


Director.