

H.R.C. 56  
Electricity

DEPARTMENT OF TRADE AND COMMERCE

ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, September 24th, 1934.

District Inspectors of Electricity and Gas:-


Dear Sirs,- Re-approval of Prepayment watthour Meters  
Types CF5k and DF5k

I beg to advise you that the following types of prepayment watthour meters, manufactured by Landis and Gyr, Inc., of Zug, Switzerland, and sold in Canada by Landis and Gyr, New York, have been approved by the National Research Council for use in Canada in the following ratings -

Type CF5k - Single phase, 2 wire, 25 cycle, maximum voltage 300 and maximum current 30 amperes with a single pole switch and 60 amperes with a double single pole switch.

Type DF5k - Single phase, 3 wire, 25 cycle, maximum voltage between outers 450 volts or 225 volts between centre and outer wires and current up to 30 amperes.

Yours truly,

  
H. J. Drey  
Director.