

N.R.C.65
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 15th, 1935.

District Inspectors of Electricity & Gas:-

Dear Sirs,

With reference to Circular N.R.C.63 dated 4th instant I beg to advise you that the Westinghouse type CS watthour meter may now be sealed provided the brass plate which is secured to the gasket in which the sealing screw is inserted fits well into the recess in the glass cover so that there will be no possible chance of the cover being twisted loose after the meter has been sealed. I am given to understand that all meters which have been shipped for some little time and which will be shipped in the future have this large brass plate secured to the gasket.

Yours truly,


Director.