## DEPARTMENT OF TRADE AND COMMERCE ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, September 6, 1935.

District Inspectors of Electricity & Gas:-

Re: Approval Type S.3, 2 element vertical bottom connected polyphase meter

Dear Sirs; -

I beg to advise you that the type S.3, 2 element vertical bottom connected polyphase meter, menufactured by the Sangamo Company Limited, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following circuits and capacities:-

Circuits - 2 phase, 3 or 4 wire; 3 phase, 3 wire; 3 phase, 4 wire with three series coil construction.

Register - Clock and cyclometer.

imperes  $-2\frac{1}{6}$ , 5, 10, 15, 25 and 50.

Voltage - 115, 230, 460 and 575.

Frequency- 25 and 60 cycle.

Divector.