

N.R.C.76
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, September 6, 1935

District Inspectors of Electricity & Gas:

Re: Approval Sangamo Type S.3, 3 element
vertical polyphase meter.

Dear Sirs;-

I beg to advise you that the Type S.3, 3 element vertical polyphase meter, manufactured by the Sangamo Company Limited, Toronto, Canada, has been approved by the National Research Council in the following circuits and capacities:

Circuit - 3 phase, 4 wire.


Register - Clock and cyclometer.

Amperes - 2½, 5, 10, 15, 25, and 50.

Voltage - 115, 230, 460 and 575.

Frequency - 25 and 60 cycle.

Yours truly,


Director.