DEPARTMENT OF TRADE AND COMMERCE ELECTRICITY AND GAS INSPECTION SERVICE

OTTAWA, October 23rd, 1935.

District Inspector of Electricity & Gas:

Dear Sirs;-

I beg to advise you that the following types of current transformers, manufactured by the Commonwealth Blee sic Corporation Limited. Welland. Ontario. have been approved by the National Research Council for use in Canada, provided, that the transformers are always used with such a burden that the error will not exceed the colerances allowed by the National Research Council Epecifications:

type 0. 5 = 100=5 amperes, 50 volt-amperes, 5000 volt, 25 and 60 cycle.

Type C. 7.5 - 100-5 amperes, 50 volt-amperes, 7500 volt, 25 and 60 cycle.

cype C.35 - 100-5 amperes, 50 volt-amperes, 15000 volt, 25 and 60 cycle.

A A

erctor.