

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, October 31st, 1935.

District Inspectors of Electricity & Gas:

Re: Approval of Packard Type A.1 Watthour meter

Dear Sirs:-

I beg to advise you that the Type A.1
watthour meter, manufactured by the Packard Electric
Limited, St. Catharines, Canada, has been approved by
the National Research Council for use in Canada in
the following capacities:

Wire - Single phase, 2 and 3 wire
Amperes - 5, 10, 15, 25 and 50.
Volts - 115, 230, 460 and 575.
Cycles - 25 and 60.
Register - Clock and cyclometer.

Yours truly,

Director.