

N.R.C. 84a  
Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, February 17, 1936.


District Inspectors of  
Electricity and Gas.

Re - Approval of Westinghouse Type C-2  
Polyphase Watthour Meter

Dear Sirs:

With reference to the approval of the Type C-2 Westinghouse Polyphase Watthour Meter, Circular N.R.C. 84, I beg to advise you that the National Research Council extends the type approval to include the metering of 3-phase 4-wire circuits with transformers, and also other special circuits, provided that the user knows definitely that the circuit conditions are such that the meter will register within the limits of accuracy allowed by the Electricity Inspection Act, 1928. (Note - This limitation applies to all types of meters - the meter installed must be suited to the load measured.)

Yours truly,

  
Director.

*for amend*