

N.R.G. 86.
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, April 30, 1936.

TO District Inspectors of
Electricity and Gas.


RE: Approval of Sangamo Two-rate
Register for Use on Type HC
Meters.

Dear Sirs:

This is to advise you that the two-rate register, manufactured by the Sangamo Electric Company Limited, Toronto, Ontario, for use on their type HC meters, has been approved by the National Research Council for use in Canada and may be admitted to verification in those capacities which, on full load of the meter, cause the lowest reading pointer of the register to make one revolution in not more than two hours.

This register is not equipped with test dials; hence the limitation in the approval.

Yours truly,


Director.