

File No.905

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, August 17, 1936.

RE: Approval of Type C-2 Polyphase  
Watthour Meter and Type C-5 Net-  
work Watthour Meter.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS


Dear Sirs:

I beg to advise you that the Type C-2 Polyphase Watthour Meter and the Type C-5 Network Watthour Meter, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario, have been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 2½, 5, 10, 15, 25, 50 and 75;  
Voltages: 115, 230, 460 and 575;  
Frequency: 25 cycle.

These meters are similar to the 60 cycle meters approved by Circulars N.R.C.84, 84a and 87, to which you are referred.

Yours truly,

  
Director.

JLS/MEE