

N.R.C. 98
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, June 25, 1937.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval Canadian Westinghouse
Type CS-2 and Type CS-5 Poly-
phase Watthour Meters.

Dear Sirs:

This is to advise you that the type CS-2 and type CS-5 polyphase watthour meters, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ontario, are approved by the National Research Council for use in Canada in the following capacities, provided that the name-plate be marked in accordance with Clauses (f) and (h) of Section 5, Pages 4 and 5, of the "Specifications of the National Research Council for Approval of Type of Watthour Meters":

Capacities

Amperes: 2.5, 5, 10, 20, 25, 40 and 50;

Voltages: 115/120, 230/240, 460/480 and
575/600;

Frequency: 60 cycles.

Yours truly,


Director.

JLS/mee