

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, July 8, 1938.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS


Re: Type DGI/C Watthour Meter

Dear Sirs:

This is to advise you that the type DGI/C single-phase, 3-wire, 60-cycle watthour meter, manufactured by Landis & Gyr Company, Zug, Switzerland, and sold in Canada by Landis & Gyr, Inc., 104 Fifth Ave., New York, has been approved by the National Research Council for use in Canada.

This meter is the same as the type CGI/C single-phase watthour meter with the exception that it is the 3-wire construction.

Yours truly,

  
J. L. Stiver,  
Director.

JLS/mee