

N.R.C. 112  
Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, August 17, 1938.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval Ferranti type "FR"  
Single-phase Watthour Meter.

Dear Sirs:

This is to advise you that the type "FR" single-phase watthour meter, manufactured by Ferranti Limited, Hollinwood, Lancashire, England, and sold in Canada by the Ferranti Electric, Limited, Toronto, Ontario, is approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25 and 50;  
Voltages: 115, 230, 575;  
Circuits: 2 and 3 wire;  
Frequency: 25 cycle;  
Dial: Clock or cyclometer;  
Case: Standard or detachable.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee