

N.R.C. 123
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, July 27, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Re: Approval of Canadian General *Electric*
Type I-305 Single-phase Watt-
hour Meter.

Dear Sirs:

This is to advise you that the type I-305 single-phase watt-hour meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, ²⁵ 50 and trans-
former type 2½ ampere rating;
Voltages: 115, 230, 575;
Frequency: 60 cycles;
Circuits: 2 and 3 wire.

Yours truly,


G. E. Stiver,
Director.

JLS/nce