

N.R.C. 124
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, July 27, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Re: Approval of Canadian General
Electric Type I-20S Single-
phase Watthour Meter.

Dear Sirs:

This is to advise you that the type I-20S single-phase watthour meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25, 50 and
transformer type $2\frac{1}{2}$ ampere
rating;
Voltages: 115, 230, 460, 575;
Frequency: 25 and 60 cycle;
Circuits: 2 and 3 wire.

Yours truly,


J. L. Stiver,
Director.

JLS/mee