

N.R.C. 126
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, August 3, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval of Sangamo Type "L2S"
60-cycle, 2-element, single disc,
Watthour Meter.

Dear Sirs:


This is to advise you that the Sangamo type "L2S" 2-element, single disc, watthour meter, manufactured by the Sangamo Electric Company, Springfield, Illinois, and sold in Canada by the Sangamo Company, Limited, Toronto, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25 and 50;

Voltages: 115, 230, 460 and 575;

Frequency: 60 cycle.

Yours truly,


J. L. Stiver,
Director.

JLS/mee