

File No. 946

L.R.C. 127
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, August 17, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Re: Approval of Packard Types
"A2", "A2A", and "A2S"
Watthour Meters.

Dear Sirs:

This is to advise you that the types "A2", "A2A" and "A2S" watthour meters, manufactured by the Packard Electric Company, Limited, St. Catharines, Ontario, have been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 10 and 15;
Voltages: 115, 230, 460 and 575;
Frequency: 25, 50 and 60 cycle;
Circuits: 2 and 3 wire.

Yours truly,



J. L. Stiver,
Director.

JLS/mee