

File No. 285

N.R.C. 129  
Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, September 11, 1939.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval Sangamo Type "ED-30"  
Combination Single-phase Watt-  
hour and Demand Meter, 50-ampere  
capacity.

---


Dear Sirs:

This is to advise you that the type "ED-30" combination single-phase watthour and demand meter, manufactured by the Sangamo Company, Limited, Toronto, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 50;  
Voltages: 115, 230;  
Frequency: 60 cycles;  
Circuits: 2 and 3 wire.

This meter has the same full scale rating on the demand meter as the regular 100-ampere "ED-3" meter, and the scale is marked accordingly.

Yours truly,

  
J. L. Stiver,  
Director.

JLS/nec