

DEPARTMENT OF TRADE AND COMMERCE

ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, October 24, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Approval Canadian General Electric Type "IM-30"
Two and Three Wire Watthour Meters With Demand
Attachment.

Dear Sirs:

This is to advise you that the type "IM-30" watthour meter with demand attachment, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following ratings and capacities, when equipped with a test dial conforming with N.R.C. Specifications, and in the case of the three-wire meter, when it has six terminals or four terminals with test links:

2 Wire - 120 V. - 60 Cycle

Full Scale Kw
Class

Ampere Meter
Rating

A D E G

2½	.9	-	-	-
5	1.8	1.25	1.5	2.9
10	3.6	2.5	-	5.7
15	4.5	3.2	-	7.2
50 x	18.0	12.5	15.0	-

3 Wire - 240 V. 60 Cycle

Full Scale Kw
Class


Ampere Meter
Rating

A D E G

5	3.6	2.5	-	5.7
10	7.2	5.1	-	-
15	9.0	6.4	-	14.0
50x	36.0	25.0	-	-

x No test dial required.

Yours truly.



J. L. Stiver,
Director.